

Annexure C

PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

No. 121/2026

Dated: 30/5/2026

It is certified that an inspection team headed by BAIJUNA Health Inspector

(Name of Officers with designation) from FHC Kottappady PHED

inspected the ST George Public School, Kottappady

(Name & Address of the school) on 17/4/2026 (date of inspection) and on the basis of

Water Test Report (Attached) bearing no. dated

of KERALA State Authority (PHED Lab) certified that the

ST George Public School (Name of school) has safe drinking water

facilities for the students and members of staff of the institution. School is also maintains the

hygienic sanitation condition in the school building & the campus as per norms prescribed by the

Central/ State/ U.T. Govt.

This certificate is valid till one year



Signature with Seal:

Name: BAIJUNA

Designation: Health Inspector

Name & Address of the Office / Department: FHC Kottappady

To

The Principal
ST George Public School Kottappady
(Name & Address of the Institution)

Note: The certificate is to be issued by authorized officer / PHED Lab / local bodies



Telephone: 0485-295332
email: qc@kwa.gov.in

KERALA WATER AUTHORITY
QUALITY CONTROL SUB DISTRICT LAB, KOTHAMANGALAM-686691
(NABL RECOGNIZED LABORATORY)
WATER TEST REPORT

Report No: KTML/142/04/26

Report Issue Date: 28.04.2026

Customer Name & Address ST GEORGE PUBLIC SCHOOL KOTTAPPADY P.O KOTTAPPADY	Date of Receipt of Payment	13.04.26
	Date of Sample received	18.04.26
	Sample given by	Medical officer FHC Kottappady
	Sample Code	142/04/26
	Sample Name	RINKING WATER
	Sample Condition	Good
	Source of Sample	WELL
	Sample Quantity	2 Litre
Test performing date: From: 21/04/2025 To: 21/04/2026		

Sl.No	Characteristics	Unit	Test Method	Acceptable Limit as per IS 10500-2012	Result
1	Colour	HAZEN	IS 3025 (Part 4)-1983(Reaffirmed 2021)	5	< 5
2	Odour		IS 3025 (Part 5)-2018	Agreeable	Agreeable
3	Turbidity	NTU	IS 3025 (Part 10)-2023	1.0	1.24
4	pH at 25° C		IS 3025 (Part 11)-1983(Reaffirmed 2022)	6.5 to 8.5	6.64
5	Total Alkalinity (as CaCO ₃)	mg/L	IS 3025 (Part 23)-2023	200	14.5
6	Total Dissolved Solids (TDS) at 180°C	mg/L	IS 3025 (Part 16)-2023	500	48
7	Total Hardness (as CaCO ₃)	mg/L	IS 3025 (Part 21)-2009(Reaffirmed 2019)	200	25.87
8	Calcium (as Ca)	mg/L	IS 3025 (Part 40)-2024	75	6.38
9	Magnesium (as Mg)	mg/L	IS 3025 (Part 46)-2023	30	2.41
10	Chloride (as Cl)	mg/L	IS 3025 (Part 32)-1988(Reaffirmed 2019)	250	14.5
11	Acidity	mg/L	IS 3025 (Part 22)-2024		8.46
12	Electrical conductivity at 25°C	(microhmhos/cm)	IS 3025 (Part 14)-2013(Reaffirmed 2019)		95
13	Iron (as Fe)	mg/L	IS 3025 (Part 53)-2024	1	0.18
14	Nitrate (as NO ₃)	mg/L	IS 3025 (Part 34/Sec.1) 2023	45	8
15	Sulphate (as SO ₄)	mg/L	IS 3025 (Part 24)-2022	200	6.95
16	Fluoride (as F)	mg/L	IS 3025 (Part 60/Sec.1) 2023	1	BDL (DL=0.2)
17	Residual Chlorine (RC)	mg/L	IS 3025 (Part 26)-2021	0.2	NIL

Remarks:

- NB-1) The result stated above related only to the sample(s) submitted for testing by the customer.
2) The samples retain for 15 days from the end date of analysis.
3) The test certificate shall not be reproduced except in full without the written approval of the Laboratory.
4) BDL = Below Detectable Limit
5) DL = Detectable Limit

End of Report



Analysed By
TECHNICAL MANAGER
SAVITHA P B

KWA/QC/SDL/KTML/P-26		Issue Date : 02.07.2021	
Rev No:03	Rev Date :-26.04.2024	Page 1 of 1	

MANAGER
St. George Public School
(Aff. to CBSE - 930927)
Kottappady P.O. - 686 692
Kothamangalam

PRINCIPAL
St. George Public School
(Aff. to CBSE - 930927)
Kottappady P.O. - 686 692
Kothamangalam



Telephone: 0485-2995723
email: qcndl@kwa.gov.in

KERALA WATER AUTHORITY
QUALITY CONTROL SUB DISTRICT LAB, KOTHAMANGALAM-686691
(NABL, RECOGNIZED LABORATORY)
WATER TEST REPORT

Report No: KTML/142/04/26

Report Issue Date 28.04.2026

Customer Name & Address ST GEORGE PUBLIC SCHOOL KOTTAPPADY P O KOTTAPPADY	Date of Receipt of Payment	13.04.26
	Date of Sample received	18.04.26
	Sample given by	Medical officer FIIC Kottappady
	Sample Code	142/04/26
	Sample Name	RINKING WATER
	Sample Condition	Good
	Source of Sample	WELL
	Sample Quantity	2 Litre
Test performing date: From: 21/04/2025 To 21/04/2026		

Sl.No	Characteristics	Unit	Test Method	Acceptable Limit as per IS 10500:2012	Result
1	Colour	HAZEN	IS 3025 (Part 4)-1983(Reaffirmed 2021)	5	<5
2	Odour		IS 3025 (Part 5)-2018	Agreeable	Agreeable
3	Turbidity	NTU	IS 3025 (Part 10)-2023	1.0	1.24
4	pH at 25° C		IS 3025 (Part 11)-1983(Reaffirmed 2022)	6.5 to 8.5	6.64
5	Total Alkalinity(as CaCO ₃)	mg/L	IS 3025 (Part 23)-2023	200	14.5
6	Total Dissolved Solids(TDS) at 180°C	mg/L	IS 3025 (Part 16)-2023	500	48
7	Total Hardness (as CaCO ₃)	mg/L	IS 3025 (Part 21)-2009(Reaffirmed 2019)	200	25.87
8	Calcium (as Ca)	mg/L	IS 3025 (Part 40)-2024	75	6.38
9	Magnesium (as Mg)	mg/L	IS 3025 (Part 46)-2023	30	2.41
10	Chloride (as Cl)	mg/L	IS 3025 (Part 32)-1988(Reaffirmed 2019)	250	14.5
11	Acidity	mg/L	IS 3025 (Part 22)-2024		8.46
12	Electrical conductivity at 25°C	(micromhos/cm)	IS 3025 (Part 14)-2013(Reaffirmed 2019)		95
13	Iron (as Fe)	mg/L	IS 3025 (Part 53)-2024	1	0.18
14	Nitrate (as NO ₃)	mg/L	IS 3025 (Part 34/Sec.1) 2023	45	8
15	Sulphate(as SO ₄)	mg/L	IS 3025 (Part 24)-2022	200	6.95
16	Fluoride(as F)	mg/L	IS 3025 (Part 60/Sec.1) 2023	1	BDL (DL=0.2)
17	Residual Chlorine (RC)	mg/L	IS 3025 (Part 26)-2021	0.2	NIL

Remarks:-

- 1) The result stated above related only to the sample(s) submitted for testing by the customer.
- 2) The samples retain for 15 days from the end date of analysis.
- 3) The test certificate shall not be reproduced except in full without the written approval of the Laboratory.
- 4) BDL= Below Detectable Limit
- 5) DL= Detectable Limit

End of Report



Analysed By
TECHNICAL MANAGER
SAMITHA P B

KWA/QCSDL/KTML/F-26	Issue Date - 02.07.2021
Rev No:03	Rev. Date :- 26.004.2024
Page 1 of 1	

MANAGER
St. George Public School
(Aff. to CBSE - 930927)
Kottappady P.O. - 686 692
Kothamangalam

PRINCIPAL
St. George Public School
(Aff. to CBSE - 930927)
Kottappady P.O. - 686 692
Kothamangalam